

## SURFACE WATER MONITORING, ROUTINE MAJOR

The 3G WSC, PWS ID TX1500006, has violated the monitoring and reporting requirements set by the Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems that treat surface water and/or ground water under the direct influence of surface water are required to submit monthly operating reports with operational data of the treatment, disinfection and quality of the water provided to their customers.

We failed to monitor and/or report the following constituents: Turbidity

This violation occurred in the monitoring period of: October 1, 2022 through October 31, 2022

Results of regular monitoring are an indicator of whether or not your drinking water is safe. We did not complete all monitoring and/or reporting for surface water constituents, and therefore, TCEQ cannot be sure of the safety of your drinking water during that time.

3G WSC has experienced an increase in the population it serves. It is now required to increase its monitoring program. We have updated the Standard Operating Procedures, as required by the TCEQ, to include analysis of all surface water constituents. Additionally, 3G WSC is in the process of installing additional online process analyzers, complete with alarms and safety lockouts.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have any questions regarding this matter, you may contact Timothy Young at 866 643-3472

Posted/Delivered on: December 30, 2022